

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE 1	OF PAGES 3
2. AMENDMENT/MODIFICATION NO. <div style="text-align: center;">A002</div>		3. EFFECTIVE DATE <div style="text-align: center;">12/14/11</div>		4. REQUISITION/PURCHASE REQ. NO. <div style="text-align: center;">AC-12-00485</div>		5. PROJECT NO. <i>(If applicable)</i>
6. ISSUED BY FAA, MIKE MONRONEY AERONAUTICAL CENTER NAS CONTRACTING TEAM AMQ-210 P O BOX 25082 OKLAHOMA CITY OK 73125-4929				7. ADMINISTERED BY <i>(If other than Item 6)</i> FOR MORE INFORMATION CONTACT: Name: Connie Houpt Telephone No. (405) 954-7820		
8. NAME AND ADDRESS OF CONTRACTOR <i>(No., street, county, State and ZIP Code)</i> All Offerors				<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION NO. <div style="text-align: center;">DTFAAC-12-R-00485</div>	
					9B. DATED <i>(SEE ITEM 11)</i> <div style="text-align: center;">11/29/11</div>	
				<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.	
*TO BE COMPLETED BY VENDOR IF NOT COMPLETE CODE					10B. DATED <i>(SEE ITEM 13)</i>	
FACILITY CODE						
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer is <input checked="" type="checkbox"/> extended <input type="checkbox"/> is not extended. NOTE: If offers are handcarried, additional time should be allowed to access the depository facility due to heightened security requirements. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:(a) By completing Item 8 and 15, and returning <u>1</u> copies of the amendment; (b) acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hours and date specified.						
12. ACCOUNTING AND APPROPRIATION DATA <i>(If required)</i>						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
<input type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: <i>(Specify authority)</i> THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT/ORDER NO. IN ITEM 10A.					
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES <i>(such as changes in paying office, appropriation data, etc.)</i> SET FORTH IN ITEM 14,					
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
<input type="checkbox"/>	D. OTHER <i>(Specify type of modification and authority)</i>					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>1</u> copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION <i>(Organized by UCF section headings, including solicitation/contract subject matter where feasible.)</i> The Request for Offer referenced in Item 9A above for MPB Restroom Renovation is amended as follows: <ul style="list-style-type: none"> • See Page 2. Reference Item 11 above. Acknowledge receipt of this amendment to: FAA Bid & Proposal Officer (AMQ-100) Room 313, Multi-Purpose Building 6500 South MacArthur Boulevard (P.O. Box 25082, Zip 73125-4933) Oklahoma City, OK 73169-4933						
15A. NAME AND TITLE OF SIGNER <i>(Type or print)</i>				16A. NAME AND TITLE OF CONTRACTING OFFICER <i>(Type or print)</i>		
15B. CONTRACTOR/OFFEROR BY _____ <i>(Signature of person authorized to sign)</i>		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY _____ <i>(Signature of Contracting Officer)</i>		16C. DATE SIGNED

Block #14—continued

Amendment continues as follows:

1. Page 29R of the SIR/RFO is replaced by Page 29R(a) to add Addendum Three as an attachment.
2. Addendum Three is added as an attachment to provide clarification and answers to questions submitted by vendors.
3. Due date for receipt of proposals has been extended to 10:00 a.m. CST, Wednesday, December 28, 2011.

PART III - SECTION J
LIST OF ATTACHMENTS

<u>ATTACHMENT</u>	<u>TITLE</u>	<u>DATE</u>	<u>NO. OF PAGES</u>
1	Project Manual, Multi-Purpose Building (MPB-24) Restroom Renovation, Work Request 2010019038	7/11	various
2	MPB-24 Restroom Renovation", Drawing No. AMP-400-D-10-019038	7/11	7
3	Standard Form 25, Performance Bond	8/97	2
4	Standard Form 25A, Payment Bond	8/97	2
5	Davis Bacon Wage Rate Decision, General Decision No. OK080034, Construction Type: Building	11/25/11	5
6	Operational Control Documents		
	AMP-400 OC-2.02-01	7/1/09	1
	AMP-400 OC-2.04.3-01	7/1/09	2
	AMP-400 OC-2.09-01	7/1/09	1
	AMP-400 OC-2.15-01	7/1/09	1
	AMP400-OC-3.1-1	5/27/09	2
	AMP400-OC-4.1-1	5/27/09	1
	AMP400-OC-5.1-1	5/27/09	2
	AMP400-OC-8.1-1	5/27/09	2
7	Reserved		
8	Addendum Two	12/12/11	3
9	Addendum Three	12/14/11	1

DATE: December 14, 2011

SUBJECT: **Addendum No. Three** to the Specifications and Drawings for the **Multi-Purpose Building Restroom Renovation**
Federal Aviation Administration, Mike Monroney Aeronautical Center, Oklahoma City, Oklahoma

This Addendum modifies and takes precedence over the original Specifications and Drawings and forms a part of the contract documents.

CLARIFICATIONS:

1. Question: The proposal documents contain 2 bid forms. One is printed in landscape and is titled: "PROPOSAL FORM" and the other is the page 2 behind the standard SF1442 titled "PART I – SECTION B". Are we required to turn in both bid forms? Does one govern in case of discrepancies?

Answer: SIR/RFO DTFAAC-12-R-00485, page 2, Part I-Section B, is the only proposal form that should be submitted with your proposal.

2. Question: The material called for at A-1, Scope of Work, #15, to be installed as the replacement for the floor tile grout bed has one particular difficulty. The Dolese mix specified is a mixed concrete material which will be very difficult to shape into a tile bed that will force water to the floor drain, as it will attempt to level itself, even though it has a high viscosity factor. This material will be very difficult to place in a condition where it is 3 ½" thick at the walls, and 1" thick at the floor drain, and have it stay that way while it sets up.

We would offer an alternative solution. The standard dry pack grout bed is made to be placed in conditions such as this, and can be installed in a much more manageable fashion. I've attached the MAPEI specification F-111, which is designed for just such a condition as this, which is to install a reinforced "floating slab" that isolates the ceramic tile from the movement of the building. In addition, it is mixed on site, and brought in concrete trucks. This dry pack bed makes it much more manageable for installing in small rooms like these.

Answer: The proposed (grout bed) solution is one of the problem conditions that we are repairing as part of this renovation because it has not performed well in this particular building, which exhibits more movement than most buildings.

There is some cracking in the floors, and an abundance of cracking at the perimeter of the rooms where the tile base meets the tile floor. The design is intended to prevent the recurrence of this problem by providing a reasonably continuous condition behind all of the tile to minimize the potential for differential movement. The design is appropriate for this condition.

Two concrete mix designs are specified, one of which (A2182) is appropriate for pumping and less stable during placement. Given the distances and the routes involved, it is unlikely that pumping will be a promising option. The other (non-pumped) concrete mix design (A2181) can be provided with a slump of 3" - upon request - to help ensure that the placement will be stable until cured.

3. Question: Would the Architect consider a reinforced grout bed in lieu of the specified Dolese concrete mix? There is some concern as to the ability to install the concrete and maintain the uniform slopes specified.

Answer: See answer to Item 2, above.